

OPPD Meter Socket Requirements

Description	Detailed Description
150 Amp, 4 terminal - single position	Outdoor NEMA 3R, UL Listing required, 16 guage steel, gray paint, ANSI C12.7, 10,000 amp shortcircuit withstand rating at rated voltage. 150 amp cont., 600V, 4T. 1 phase 3 wire. Line lugs to 250 MCM Cu-Al. Cu-Al ground term #6 minimum. Provisions to install 5th terminal at 9 O'Clock position. Lever bypass not required for residential use. For OH feed with hub opening without blank cover or hub. 2.5" KO in bottom middle, 2.0" KO's on bottom left & right and on each side panel and on back. 1/4" KO in bottom. KO on cover above the cover latch for a standard InnerTite barrel lock. Ringless.
	Eaton/Cutler Hammer part # 1009740-CH / OPPD Approved for residential use only.
	Durham part # 1009740 / OPPD Approved for residential use only.
	Siemens/Talon/Landis & GYR part# UAT314-0GD / OPPD Approved for residential.
	Midwest part # 1009740-MEP / OPPD Approved for residential use only.
	Milbank part# S4028-RL-OPPD-DES / Approved by OPPD but not UL listed. Remaining stock at OPPD will be issued. [Will notify City of Omaha when stock depleted.]
	Milbank part# U5168-XTL-150-IL (w/150 amp interior bkr pnl) / OPPD Approved for residential use only.
	Milbank part# U8084-RL-TG-IL (for 5th term use cat number K5T) / OPPD Approved for residential and commercial use.
	Square D part # 1009740-SQD / OPPD Approved for residential use only.
200 Amp, 4 terminal - Single position	Outdoor NEMA 3R, UL Listing required, 16 guage steel, gray paint, ANSI C12.7, 10,000 amp shortcircuit withstand rating at rated voltage. 200 amp cont., 600V, 4T. 1 phase 3 wire. Line lugs to 350 MCM Cu-Al. Cu-Al ground term #6 minimum. Provisions to install 5th terminal at 9 O'Clock position. Lever bypass not required for residential use. Make-before-break lever bypass required for commercial use. For OH/UG feed with hub opening & a blank cover. KOs to 2.5". Two on bottom center and right, one on each side pnl and on back. 1/4" KO in bottom. KO on cover above the cover latch for a standard InnerTite barrel lock. Ringless.
	Eaton/Cutler Hammer UT-RS213ACH / OPPD Approved for residential use only.
	Eaton/Cutler Hammer part # 1009741-CH / OPPD Approved for residential use only.
	Eaton/Cutler Hammer part # 1009742-CH / OPPD Approved for residential use only.
	Eaton/Cutler Hammer part # 1010200-CH (w/ 2- 200 Amp brk pnl) / OPPD Approved fo residential and commercial use.
	Durham part # 1006101 / OPPD Approved for residential and commercial use.
	Durham part # 1009741 / OPPD Approved for residential use only.
	Durham part # 1009742 / OPPD Approved fo residential and commercial use.
	Durham part # 1010200 (w/ 2- 200 Amp brk pnl) / OPPD Approved fo residential and commercial use.
	Siemens/Talon/Landis & GYR part# 40405-0BNU / OPPD Approved for commercial use.
	Midwest part # 1009741-MEP / OPPD Approved for residential use only.
	Midwest part # 1009742-MEP / OPPD Approved for residential use only.
	Midwest part # 1010200-MEP (w/ 2- 200 Amp brk pnl) / OPPD Approved fo residential and commercial use.
	Milbank part# U5168-XTL-200-IL (w/200 Amp interior bkr pnl) / OPPD Approved for residential use only.
	Milbank parr U5871 with barrel lock provisions. OPPD Approved for residential and commercial use. 10/14/2008 DGL
	Milbank U5871, U5872 Single phase meter socket with breaker and by-pass. Approved for residential and commercial. 5th terminal is available.
	Milbank part# U7040-XL-TG--IL / OPPD Approved for residential and commercial use.
	Milbank part # U7043-XL-TG-IL (Two 3" KO's in bottom) / OPPD Approved for residential and commercial use.
	Milbank part # U9550-XL-5T9 (w/lever bypass & 5th term in 9 o'clock pos) / OPPD Approved for residential and commercial use.

OPPD Meter Socket Requirements

Description	Detailed Description
	Milbank part # U9551-RXL-5T9-IL (w/lever bypass & factory installed 5th term in 9 o'clock pos) / OPPD Approved
	Milbank part # U9801-RXL (w/lever bypass) / OPPD Approved for residential and commercial use.
	Square D part # 1009741-SQD / OPPD Approved for residential use only.
	Square D part # 1009742-SQD / OPPD Approved for residential use only.
	Square D part # 1010200-SQD (w/ 2- 200 Amp brk pnl) / OPPD Approved fo residential and commercial use.
	Square D part # UTRS213B / OPPD Approved for residential use only
	Siemens/Talon/Landis & GYR part# UAT417-XGD / OPPD Approved for residential.
	Siemens/Talon/Landis & GYR part# UAT817-XGD / OPPD Approved for residential.
200 Amp, 7 terminal - Single position	Outdoor NEMA 3R, UL listing required, 16 guage steel, gray paint, ANSI C12.7, 10,000 amp shortcircuit withstand rating at rated voltage. 200 amp cont., 600V, 7T. 3 phase 4 wire WYE or Delta. Line / load / neutral lugs to 350 MCM Cu-Al, ground term to #2 Cu-Al. Make-before-break lever bypass required. For OH/UG feed with hub opening & a blank cover. KO's to 2.5", Three on bottom, one on each side panel & one on back. 1/4" KO in bottom. KO on cover above the cover latch for a standard InnerTite barrel lock. Ringless.
	Eaton/Cutler Hammer part # 1009743-CH / OPPD Approved for commercial use.
	Durham part # 1009743 / OPPD Approved for commercial use.
	Siemens/Talon/Landis & GYR part# 40407-01NU / OPPD Approved for commercial use.
	Midwest part # 1009743-MEP / OPPD Approved for commercial use.
	Milbank part# U3781-RXL-IL (OH/UG, w/lever bypass) - side wireway, includes circuit breaker/ OPPD Approved for commercial use.
	Milbank part# U7422-RL-IL (OH/UG) / Approved until OPPD stock depleted.
	Milbank part# U9701-RL-IL (OH/UG, w/lever bypass) / OPPD Approved for commercial use.
	Square D part # 1009743-SQD / OPPD Approved for commercial use.
320 Amp, 4 Terminal - Single position	Outdoor NEMA 3R, UL listing required, 16 guage steel, gray paint, ANSI C12.7 10,000 amp shortcircuit withstand rating at rated voltage. 320 amp cont., 600V, 4T. 1 phase 3 wire. Line / load / neutral connector 3/8" studs, ground term to 1/0 Cu-Al. Make-before-break lever bypass required. Provisions for 5th terminal at 9 o'clock position. OH/UG feed with hub opening and a blank cover. Side wire-way, KO's to 4.0", two on bottom right & left side. KO's to 3.0" one on bottom center and one on each side panel & one on back. 1/4" KO in bottom. KO on cover above the cover latch for a standard InnerTite barrel lock. Ringless.
	Eaton/Cutler Hammer part # 1009744-CH / OPPD Approved for residential and commercial use.
	Durham part # 1009744 / OPPD Approved for residential and commercial use.
	Siemens/Talon/Landis & GYR part# LG0404L1400RLM / OPPD Approved for commercial and residential use. OH/UG w/heavy duty lever bypass- side wire way, includes two - 200 /amp breakers.
	Siemens/Talon/Landis & GYR part# 47605-82 / OPPD Approved for Residential / Commercial use.
	Siemens/Talon/Landis & GYR part# 48004-82 / OPPD Approved for residential and commercial use.
	Midwest part # 1009744-MEP / OPPD Approved for residential and commercial use.
	Milbank Part# U1797-O-K3L-K2L-IL (UG) w/hvy duty lever bypass - side wireway / OPPD Approved
	Milbank part # U4905-RXL-K3-K2-IL (OH/UG) w/hvy duty lever bypass - side wireway / OPPD Approved
	Milbank Part# U5059-X-2/200-K3L-IL (UG) w/heavy duty lever bypass - side wireway, includes two - 200 amp breakers / OPPD Approved

OPPD Meter Socket Requirements

Description	Detailed Description
	Siemens part# MM0404L1400RLM / OPPD Approved for commercial and residential use. OH/UG w/heavy duty lever bypass- side wire way, includes two - 200 /amp breakers.
	Square D part # 1009744-SQD / OPPD Approved for residential and commercial use.
320 Amp, 7 Terminal - Single position	Outdoor NEMA 3R, UL listing required, 16 guage steel, gray paint, ANSI C12.7 10,000 amp shortcircuit withstand rating at rated voltage. 320 amp cont., 600V, 7T. 3 phase 4 wire WYE or Delta. OH/UG feed with hub opening and a blank cover. Side wire-way. Line / load / neutral connector 3/8" studs, ground term to 1/0 Cu-Al. Make-before-break Lever bypass required. KO's to 4.0", two on the bottom right & left side. KO's to 3.0" one on the bottom center & one on each side panel and on the back. 1/4" KO in bottom. KO on cover above the cover latch for a standard InnerTite barrel lock. Ringless.
	Eaton/Cutler Hammer part # 1009745-CH / OPPD Approved for commercial use.
	Durham part # 1009745 / OPPD Approved for commercial use.
	Siemens/Talon/Landis & GYR part# 48707-029 / OPPD Approved for commercial use.
	Midwest part # 1009745-MEP / OPPD Approved for commercial use.
	Milbank part# U2594-X-IL (OH/UG), w/hvy duty bypass - side wireway / OPPD Approved for commercial use.
	Milbank part # U4659-X-IL (OH/UG), w/hvy duty bypass - side wireway / OPPD Approved for commercial use.
	Square D part # 1009745-SQD / OPPD Approved for commercial use.
200 Amp, 4 Terminal - Two position	Outdoor NEMA 3R, UL listing required, 16 guage steel, gray paint, ANSI C12.7 10,000 amp shortcircuit withstand rating at rated voltage. 200 amp cont per position, 300V, 4T. 1 phase 3 wire. Center feed - horizontal layout. Line / neutral lugs to 500 MCM CU-AL., Load / neutral lugs to 350 MCM Cu-Al. ground lug to #2 CU-AL. For OH/UG feed with hub opening & a blank cover. Lugs setup for UG feed. KOs to 3.0" on bottom center. KO's to 2.5" one on the bottom & one on the side panel and on the back for each position. 1/4" KO in bottom. KO on cover above the cover latch for a standard InnerTite barrel lock. Ringless.
	Cutler Hammer part # 1009746-CH / OPPD Approved for residential use only.
	Durham part # 1009746 / OPPD Approved for residential use only.
	Siemens/Talon/Landis & GYR part# UA2717-ZGD / OPPD Approved for residential use only.
	Midwest part # 1009746-MEP / OPPD Approved for residential use only.
	Milbank part# U1252-X-K3-IL / OPPD Approved for residential use only.
	Square D part # 1009746-SQD / OPPD Approved for residential use only.
150 Amp, 4 Terminal - Two position	Outdoor NEMA 3R, UL listing required, 16 guage steel, gray paint, ANSI C12.7 10,000 amp shortcircuit withstand rating at rated voltage. 150 amp cont. per position, 300V, 4T. 1 phase 3 wire. End feed - horizontal layout. Line / neutral lugs to 350 MCM Cu-Al. Load lugs to 250 MCM Cu-Al. Ground lug to #2 Cu-Al. For OH/UG feed with hub opening & a blank cover. Lugs setup for OH feed. KO' to 2.5" on each side of the service can feed. KO's to 2.0" one on the bottom & one the side panel and one the back of each position. 1/4" KO in bottom. KO on cover above each cover latch for a standard InnerTite barrel lock. Ringless.
	Eaton/Cutler Hammer part # 1009747-CH / OPPD Approved for residential use only.
	Durham part # 1009747 / OPPD Approved for residential use only.
	Midwest part # 1009747-MEP / OPPD Approved for residential use only.
	Square D part # 1009747-SQD / OPPD Approved for residential use only.

OPPD Meter Socket Requirements

Description	Detailed Description
150 Amp, 4 Terminal - Three position	Outdoor NEMA 3R, UL listing required, 16 guage steel, gray paint, ANSI C12.7, 10,000 amp shortcircuit withstand rating at rated voltage. 150 amp cont. per position, 300V, 4T. 1 phase 3 wire. Line / Neutral lugs to 350 MCM Cu-Al. Load lugs to 250 MCM Cu-Al Ground lug to #2 Cu-Al. End feed - horizontal layout. For OH feed with hub opening without blank cover or hub. Lugs setup for OH feed. KO to 2.5" on each side of the service can feed. KO's to 2.0" one on the bottom & one on the side panel and one on the back for each position. 1/4" KO in bottom. KO on cover above each cover latch for a standard InnerTite barrel lock. Ringless
	Eaton/Cutler Hammer part # 1009748-CH / OPPD Approved for residential use only.
	Durham part # 1009748 / OPPD Approved for residential use only.
	Midwest part # 1009748-MEP / OPPD Approved for residential use only.
	Milbank part# U1253-X-K3-IL (200 amp) / OPPD Approved for residential use only.
	Square D part # 1009748-SQD / OPPD Approved for residential use only.
100 Amp Temporary pole socket	Outdoor, Steel, gray paint. 100 amp minimum cont., 600V, 4T, 1 phase 3 wire, with a 5th terminal installed at the 9 O'Clock position.
	GE Cat# 301X309000, Type R-2, Hub 2-1 - OPPD Approved
	Milbank part# S4028-RL-OPPD-DES / Approved by OPPD but not UL listed. Remaining stock at OPPD will be issued if OK with City of Omaha.
100 Amp, 4 Terminal, Residential Overhead Farm Assembly - single position	Outdoor NEMA 3R, UL Listing required, 16 guage steel, gray paint, ANSI C12.7, 10,000 amp shortcircuit withstand rating at rated voltage. 100 amp cont., 600V 4T, 1 phase 3 wire. Provisions to install 5th terminal at 9 O'Clock position. For OH feed. KO on cover latch for a standard InnerTite barrel lock or equivalent locking provision for cover. Ringless.
	Eaton/Cutler Hammer part# DB122N0B-CH / OPPD Approved
	Durham part# DB122N0B / OPPD Approved
200 Amp, 4 Terminal, Residential Overhead Farm Assembly - single position	Outdoor NEMA 3R, UL Listing required, 16 guage steel, gray paint, ANSI C12.7, 10,000 amp shortcircuit withstand rating at rated voltage. 200 amp cont., 600V 4T, 1 phase 3 wire. Provisions to install 5th terminal at 9 O'Clock position. For OH feed. KO on cover latch for a standard InnerTite barrel lock or equivalent locking provision for cover. Ringless.
	Eaton/Cutler Hammer part# DC222W1B-CH / OPPD Approved
	Durham part# DC222W1B / OPPD Approved